Titen HD® Design Information - Concrete

Titen HD[®] Tension Strength Design Data¹

Characteristic	Sumbol	Unito		Nominal Anchor Diameter, d_a (in.)								
Gharacteristic	Symbol	Units	1/	′4 ⁹	3,	/8	1,	/ 2	5/	8 ⁹	3,	4
Nominal Embedment Depth	h _{nom}	in.	1 5⁄8	21⁄2	21⁄2	31⁄4	31⁄4	4	4	5½	5½	6¼
		Steel S	Strength	in Tensior	ı							
Tension Resistance of Steel	N _{sa}	lb.	5,1	195	10,	890	20,	130	30,	360	45,	540
Strength Reduction Factor — Steel Failure	ϕ_{sa}	—	0.65 ²									
	Concr	ete Brea	kout Stre	ength in T	ension ^{6,8}							
Effective Embedment Depth	h _{ef}	in.	1.19	1.94	1.77	2.40	2.35	2.99	2.97	4.24	4.22	4.86
Critical Edge Distance ⁶	C _{ac}	in.	3	6	211/16	35⁄8	3%16	41⁄2	41⁄2	6 3⁄8	63⁄8	75⁄16
Effectiveness Factor — Uncracked Concrete	<i>k</i> _{uncr}	—	30 24									
Effectiveness Factor — Cracked Concrete	k _{cr}		17									
Modification Factor	$\Psi_{c,N}$	—	1.0									
Strength Reduction Factor — Concrete Breakout Failure	ϕ_{cb}	_					0.6	65 ⁷				
		Pullout	Strength	in Tensio	n ⁸							
Pullout Resistance, Uncracked Concrete (f'c=2,500 psi)	N _{p,uncr}	lb.	3	3	2,7004	3	3	3	3	9,8104	3	3
Pullout Resistance, Cracked Concrete (f'c=2,500 psi)	N _{p,cr}	lb.	3	1,9054	1,2354	2,7004	3	3	3,2604	5,5704	6,0704	7,1954
Strength Reduction Factor — Concrete Pullout Failure	$\phi_{ ho}$	_					0.6	65⁵				
Breako	ut or Pullou	ut Streng	th in Ten	sion for S	eismic A	pplicatior	1S ⁸					
Nominal Pullout Strength for Seismic Loads (f'c=2,500 psi)	N _{p,eq}	lb.	3	1,9054	1,2354	2,7004	3	3	3,2604	5,5704	6,0704	7,1954
Strength Reduction Factor — Breakout or Pullout Failure	ϕ_{eq}	—					0.6	65⁵				
The information presented in this table is to be used in conjunction with the design criteria of ACI 318 Appendix D, except as modified below. The value of ϕ applies when the load combinations of ACI 318 Section 9.2 are $(1) \psi_{cp,N} = 1.0 \text{ if } c_{a,min} \ge c_{ac} \text{ or } (2) \psi_{cp,N} = \frac{c_{a,min}}{c_{ac}} \ge \frac{1.3N_{ef}}{c_{ac}} \text{ if } c_{a,min} < c_{ac}$ The modification factor, $\psi_{cp,N}$ is applied to the nominal concrete breakout												

- 2. The value of ϕ applies when the load combinations of ACI 318 Section 9.2 are used. If the load combinations of ACI 318 Appendix C are used, refer to Section D.4.4 to determine the appropriate value of ϕ . Anchors are considered brittle steel elements.
- 3. Pullout strength is not reported since concrete breakout controls.
- Adjust the characteristic pullout resistance for other concrete compressive strengths by multiplying the tabular value by (f⁺_{c,specified} / 2,500)^{0.5}.
- 5. The value of ϕ applies when both the load combinations of ACI 318 Section 9.2 are used and the requirements of Section D.4.3(c) for Condition B are met. If the load combinations of ACI 318 Appendix C are used, refer to Section D.4.4 to determine the appropriate value of ϕ .
- 6. The modification factor $\Psi_{cp,N} = 1.0$ for cracked concrete. Otherwise, the modification factor for uncracked concrete without supplementary reinforcement to control splitting is either:
- The value of ϕ applies when both the load combinations of ACI 318 Section 9.2 are used and the requirements of Section D.4.3(c) for Condition B are met. If the load combinations of ACI 318 Section 9.2 are used and the requirements of Section D.4.3(c) for Condition B are met. If the load combinations of ACI 318 Section 9.2 are used and the
- requirements of Section D.4.3(c) for Condition A are met, refer to Section D.4.3 to determine the appropriate value of ϕ . If the load combinations of ACI 318 Appendix C are used, refer to Section D.4.4 to determine the appropriate value of ϕ .
- 8. For sand-lightweight concrete, in lieu of ACI 318 Section D.3.6, modify the value of concrete breakout strength, $N_{p,cr}$, $N_{p,uncr}$ and N_{eq} by 0.6. All-lightweight concrete is beyond the scope of this table.
- 9. Data for ¼" anchor is valid only for THDB25 series. Data for %" anchor is valid only for THDB62 series.

There is a check of the sign bala	Titen H	ID® S	Shear	Strength	Design	Data ¹
-----------------------------------	---------	-------	-------	----------	--------	-------------------

			Nominal Anchor Diameter d. (in)									
Characteristic	Symbol	Units	1/2	1 ⁵	3	/8	1/	2	5/2 5/2	, ⁵	3/	, 4
Nominal Embedment Depth	h _{nom}	in.	15/8 21/2 21/2 31/4			3¼	4	4	5½	5½	6¼	
		Steel	Strength	in Shear								
Shear Resistance of Steel	V _{sa}	lb.	2,0	20	4,4	460	7,4	55	10,0	000	16,8	340
Strength Reduction Factor — Steel Failure	ϕ_{sa}	_	0.60 ²									
	Con	crete Bre	akout Str	ength in	Shear ⁶							
Outside Diameter	da	in.	0.25 0.375 0.500 0.625				625	0.7	50			
Load Bearing Length of Anchor in Shear	le	in.	1.19	1.94	1.77	2.40	2.35	2.99	2.97	4.24	4.22	4.86
Strength Reduction Factor — Concrete Breakout Failure	ϕ_{cb}	-					0.7	'0 ⁴				
	Co	ncrete P	ryout Stre	ength in S	Shear							
Coefficient for Pryout Strength	K _{cp}	lb.			1.0					2.0		
Strength Reduction Factor — Concrete Pryout Failure	ϕ_{cp}	—					0.7	'0 ⁴				
Steel Strength in Shear for Seismic Applications												
Shear Resistance for Seismic Loads	Veq	lb. 1,695 2,855 4,790 8,000					9,3	50				
Strength Reduction Factor — Steel Failure	ϕ_{eq}		— 0.60 ²									
 The defense attention constraints at the state state to the state of t		and the second		0	+! D	4 4 4						

 The information presented in this table is to be used in conjunction with the design criteria of ACI 318 Appendix D, except as modified below.
 The value of \u03c6 applies when the load combinations of ACI 318 Section 9.2 are used.

refer to Section D.4.4 to determine the appropriate value of ϕ .

only for THDB62 series.

4. The value of φ applies when both the load combinations of ACI 318 Section 9.2 are used and the requirements of Section D.4.3(c) for Condition B are met. If the load combinations of ACI 318 Appendix C are used, refer to Section D.4.4 to determine the appropriate value of φ.
5. Data for ¼" anchor is valid only for THDB25 series. Data for ¼" anchor is valid

3. The value of \$\phi\$ applies when both the load combinations of ACI 318 Section 9.2 are used and the requirements of Section D.4.3(c) for Condition B are met. If the load combinations of ACI 318 Section 9.2 are used, and the requirements of Section D.4.3(c) for Condition A are met, refer to Section D.4.3 to determine the appropriate value of \$\phi\$. If the load combinations of ACI 318 Appendix C are used, * See page 12 for an explanation of the load table icons.

If the load combinations of ACI 318 Appendix C are used, refer to Section D.4.4 to

determine the appropriate value of ϕ . Anchors are considered brittle steel elements.

6. For sand-lightweight concrete, in lieu of ACI 318 Section D.3.6, modify the value of concrete breakout strength by 0.6. All-lightweight concrete is beyond the scope of this table.

Titen HD® Tension and Shear Strength Design Data for the Soffit of Normal-Weight or Sand-Lightweight Concrete over Metal Deck^{1,6,8}

				Nominal Anchor Diameter, d _a (in.)								
Characteristic	Symbol	Unito	Lower Flute						Upper Flute			
Gliaracteristic	Symbol	Units	Figure 2		Figure 1				Figure 2		Figure 1	
			1/	4 ⁸	3⁄/8		1,	/2	1⁄48		3⁄8	1⁄2
Nominal Embedment Depth	h _{nom}	in.	1 5⁄8	21/2	1 1 1/8	21⁄2	2	31⁄2	1 5⁄8	21⁄2	1 1 1/8	2
Effective Embedment Depth	h _{ef}	in.	1.19	1.94	1.23	1.77	1.29	2.56	1.19	1.94	1.23	1.29
Pullout Resistance, concrete on metal deck (cracked) ^{2,3,4}	N _{p,deck,cr}	lb.	420	535	375	870	905	2,040	655	1,195	500	1,700
Pullout Resistance, concrete on metal deck (uncracked) ^{2,3,4}	Np, deck, uncr	lb.	995	1,275	825	1,905	1,295	2,910	1,555	2,850	1,095	2,430
Steel Strength in Shear, concrete on metal deck5	V _{sa, deck}	lb.	1,335	1,745	2,240	2,395	2,435	4,430	2,010	2,420	4,180	7,145
Steel Strength in Shear, Seismic	Vsa, deck,eg	lb.	870	1,135	1,434	1,533	1,556	2,846	1,305	1,575	2,676	4,591

IBC

1. The information presented in this table is to be used in conjunction with the design criteria of ACI 318 Appendix D, except as modified below.

2. Concrete compressive strength shall be 3,000 psi minimum. The characteristic pullout resistance for greater compressive strengths shall be increased by multiplying the tabular value by $(f'_{c,specified}/3,000)^{0.5}$

3. For anchors installed in the soffit of sand-lightweight or normal-weight concrete over metal deck floor and roof assemblies, as shown in Figure 1 and Figure 2, calculation of the concrete breakout strength may be omitted.

4. In accordance with ACI 318 Section D.5.3.2, the nominal pullout strength in cracked concrete for anchors installed in the soffit of sand-lightweight or normal-weight concrete over metal deck floor and roof assemblies Np. deck.cr

loads, the normal pullout strength in uncracked concrete $N_{p,deck,uncr}$ shall be substituted for N_{p.uncr} 5. In accordance with ACI 318 Section D.6.1.2(c), the shear strength for anchors installed in the soffit of sand-lightweight or normal-weight concrete

over metal deck floor and roof assemblies $V_{sa,deck}$ and $V_{sa,deck,eq}$ shall be substituted for V_{sa} .

shall be substituted for $N_{p,cr}$. Where analysis indicates no cracking at service

- 6. Minimum edge distance to edge of panel is 2hef.
- 7. The minimum anchor spacing along the flute must be the greater of 3h_{ef}, or 1.5 times the flute width.
- 8. Data for 1/4" anchor is valid only for THDB25 series.

Data in the Tonside of No	ormal-Weight (Concrete	<i>.</i>
or Sand-Lightweight Cor	icrete over Me	tal Deck	
5 5			

			Nominal Anchor Diameter, d _a			
Design Information	Symbol	Units	Figure 3	Figure 2		
			9/4 ^{**}	% 8		
Nominal Embedment Depth	h _{nom}	in.	1 5⁄8	21⁄2		
Effective Embedment Depth	h _{ef}	in.	1.19	1.77		
Minimum Concrete Thickness	h _{min,deck}	in.	21⁄2	31⁄4		
Critical Edge Distance	Cac,deck,top	in.	3¾	71⁄4		
Minimum Edge Distance	Cmin, deck, top	in.	31⁄2	3		
Minimum Spacing	Smin,deck,top	in.	31⁄2	3		

- 1. For anchors installed in the topside of concrete-filled deck assemblies, as shown in Figures 2 and 3, the nominal concrete breakout strength of a single anchor or group of anchors in shear, V_{cb} or V_{cbg} , respectively, must be calculated in accordance with ACI 318 D.6.2, using the actual member thickness, $h_{\min, deck}$, in the determination of A_{vc} .
- 2. Design capacity shall be based on calculations according to values in the tables featured on pages 185 and 186.
- 3. Minimum flute depth (distance from top of flute to bottom of flute) is 11/2 inch (see Figures 2 and 3).
- 4. Steel deck thickness shall be minimum 20 gauge.
- 5. Minimum concrete thickness $(h_{min,deck})$ refers to concrete thickness above upper flute (see Figures 2 and 3).







Figure 2. Installation of 3%" Diameter Anchors in the Topside and 1/4" Diameter Anchors in the Soffit of Concrete over Metal Deck



Figure 3. Installation of 1/4" Diameter Anchors in the Topside of Concrete over Metal Deck

SIMPSOI

Strong

Titen HD® Design Information - Concrete



IBC

IBC

Titen HD[®] Tension Design Strengths in Normal-Weight Concrete (f'_c = 2,500 psi)

		Min	Critical	Minimum	Tension Design Strength (lb.)									
Anchor Dia.	Nominal Embed.	Concrete Thickness	Edge Distance	Edge Distance	Edge [Distances =	c _{ac} on all si	des	Edge Distances = c_{min} on one side and c_{ac} on three sides					
()	(in.)	h _{min}	Cac	C _{ac} C _{min}		SDC A-B ⁵		SDC C-F ^{6,7}		SDC A-B ⁵		SDC C-F ^{6,7}		
	()	(in.)	(in.)	(In.)	Uncracked	Cracked	Uncracked	Cracked	Uncracked	Cracked	Uncracked	Cracked		
17	1 5%	31⁄4	3	11⁄2	1,265	715	950	540	660	630	495	470		
'/4	21/2	31/2	6	11⁄2	2,110	1,240	1,580	930	660	965	495	725		
3/	21/2	4	211/16	1 3⁄4	1,755	805	1,315	600	1,350	805	1,015	600		
9/8	31⁄4	5	3%	1 3⁄4	2,900	1,755	2,175	1,315	1,810	1,290	1,360	970		
1/	31⁄4	5	3%16	1 3⁄4	2,810	1,990	2,105	1,495	1,765	1,265	1,325	950		
72	4	61⁄4	41/2	1 3⁄4	4,035	2,855	3,025	2,140	2,285	1,620	1,710	1,220		
5/	4	6	41/2	1 3⁄4	3,990	1,975	2,995	1,480	2,250	1,610	1,690	1,210		
%8	51/2	81⁄2	6%	13⁄4	6,375	3,620	4,780	2,715	3,390	2,405	2,540	1,805		
3⁄4	51/2	83⁄4	6%	1 3⁄4	6,760	3,945	5,070	2,960	3,355	2,395	2,515	1,795		
	61⁄4	10	75⁄16	13⁄4	8,355	4,675	6,265	3,510	3,990	2,835	2,990	2,125		

1. Tension design strengths are based on the strength design provisions of ACI 318-11 Appendix D.

2. Tabulated values are for a single anchor with no influence of another anchor.

3. Interpolation between embedment depths is not permitted.

4. Strength reduction factor, ϕ , is based on using a load combination from ACI 318-11 Section 9.2.

5. The tension design strength listed for SDC (Seismic Design Category) A-B may also be used in SDC C-F when the tension component of the strength-level seismic design load on the anchor does not exceed 20% of the total factored tension load on the anchor associated with the same load combination.

6. When designing anchorages in SDC C-F, the designer shall consider the ductility requirements of ACI 318-11 Section D.3.3.

7. Tension design strengths in SDC C-F have been adjusted by 0.75 factor in accordance with ACI 318-11 Section D.3.3.4.4.

Titen HD® Allowable Tension Loads in Normal-Weight Concrete (f'_c = 2,500 psi) - Static Load



1. Allowable tension loads are calculated based on the strength design provision of ACI 318-11 Appendix D using a conversion factor of $\alpha = 1.4$. The conversion factor α is based on the load combination 1.2D + 1.6L assuming 50% dead load and 50% live load: 1.2(0.5) + 1.6(0.5) = 1.4.

2. Tabulated values are for a single anchor with no influence of another anchor.

3. Interpolation between embedment depths is not permitted.

Titen HD[®] Allowable Tension Loads in Normal-Weight Concrete ($f'_c = 2,500$ psi) — Wind Load

	IBC		*
--	-----	--	---

	No				Allowable Tension Load (lb.)						
Anchor Dia. (in.)	Embed. Depth	Thickness h _{min}	Distance c _{ac}	Distance c _{min}	Edge Distances	Edge Distances = c_{ac} on all sides		Edge Distances = c_{min} on one side and c_{ac} on three sides			
	()	()	()	()	Uncracked	Cracked	Uncracked	Cracked			
17	1 5%	31⁄4	3	1 1/2	760	430	395	380			
74	21/2	31⁄2	6	1 1/2	1,265	745	395	580			
3/6	21⁄2	4	211/16	1 3⁄4	1,055	485	810	485			
78	31⁄4	5	35%	1 3⁄4	1,740	1,055	1,085	775			
14	31⁄4	5	3%16	1 3⁄4	1,685	1,195	1,060	760			
72	4	61⁄4	4 1/2	1 3⁄4	2,420	1,715	1,370	970			
5/	4	6	4 1/2	1 3⁄4	2,395	1,185	1,350	965			
78	51/2	81/2	63⁄8	1 3⁄4	3,825	2,170	2,035	1,445			
3⁄4	51/2	83⁄4	63%	1 3⁄4	4,055	2,365	2,015	1,435			
	61⁄4	10	75/16	1 3⁄4	5,015	2,805	2,395	1,700			

1. Allowable tension loads are calculated based on the strength design provision of ACI 318-11 Appendix D using a conversion factor of $\alpha = 1.67$. The conversion factor α is based on the load combination assuming 100% wind load.

2. Tabulated values are for a single anchor with no influence of another anchor.

3. Interpolation between embedment depths is not permitted.

Titen HD[®] Allowable Tension Loads in Normal-Weight Concrete (f' $_{\rm c}$ = 2,500 psi) — Seismic Load



1. Allowable tension loads are calculated based on the strength design provision of ACI 318-11 Appendix D using a conversion

factor of $\alpha = \frac{1}{2}$. The conversion factor α is based on the load combination assuming 100% seismic load.

2. Tabulated values are for a single anchor with no influence of another anchor.

3. Interpolation between embedment depths is not permitted.

4. The allowable tension load listed for SDC (Seismic Design Category) A-B may also be used in SDC C-F when the tension component of the strength-level seismic design load on the anchor does not exceed 20% of the total factored tension load on the anchor associated with the same load combination.

5. When designing anchorages in SDC C-F, the designer shall consider the ductility requirements of ACI 318-11 Section D.3.3.

6. Tension design strengths in SDC C-F have been adjusted by 0.75 factor in accordance with ACI 318-11 Section D.3.3.4.4.

SIMPSOI

Strong-1

Titen HD® Tension Design Strengths in Soffit of Normal-Weight or Sand-Lightweight Concrete-Filled

	Profile St	eel Deck	Assembl	it or ies (f' _c = (3,000 psij)	IBC					
	Tension Design Strength (lb.)											
d Lower Flute Upper Flute												
SDC A-B ⁵ SDC C-F ^{6,7} SDC A-B ⁵ SDC C-F ^{6,7}												
	Uncracked	Cracked	Uncracked	Cracked	Uncracked	Cracked	Uncracked	Cracke				

			Uncracked	Grackeu	Uncracked	Сгаскей	Uncrackeu	Сгаскей	Uncracked	Grackeu
1⁄4	1%	2 1/2	645	275	485	205	1,010	425	760	320
74	21/2	4	830	350	620	260	1,855	775	1,390	585
3/	1 7⁄8	2 1/2	535	245	400	185	710	325	535	245
98	21⁄2	3 5/8	1,240	565	930	425	_	—	—	—
1/	2	2 %	840	590	630	440	1,580	1,105	1,185	830
/2	31⁄2	51⁄4	1,890	1,325	1,420	995	—	_		_

1. Tension design strengths are based on the strength design provisions of ACI 318-11 Appendix D.

2. Tabulated values are for a single anchor with no influence of another anchor.

Minimum End

(in.)

Distance cm

3. Interpolation between embedment depths is not permitted.

Nominal

Embed. Depth

(in.)

Anchor Dia.

(in.)

5. The tension design strength listed for SDC (Seismic Design Category) A-B may also be used in SDC C-F when the tension component of the strength-level seismic design load on the anchor does not exceed 20% of the total factored tension load on the anchor associated with the same load combination.

6. When designing anchorages in SDC C-F, the designer shall consider the ductility requirements of ACI 318-11 Section D.3.3.

7. Tension design strengths in SDC C-F have been adjusted by 0.75 factor in accordance with ACI 318-11 Section D.3.3.4.4.

8. Installation must comply with Figure 1 on page 187.

Titen HD® Allowable Tension Loads in Soffit of Normal-Weight or Sand-Lightweight Concrete-Filled Profile Steel Deck Assemblies $(f'_{2} = 3.000 \text{ psi})$ Static Load

	$(\Gamma_{\rm c} = 0,000 {\rm ps}) = 0$ and $\Gamma_{\rm c}$												
	Nominal Embed.	Minimum End	Allowable Tension Load (lb.)										
Anchor Dia.	Depth	Distance c _{min}	stance c _{min} Lower Flute U		Uppei	^r Flute							
()	(in.)	(in.)	Uncracked	Cracked	Uncracked	Cracked							
1/	1 5%	21/2	460	195	720	305							
74	21/2	4	595	250	1,325	555							
3/	1 7/8	21/2	380	175	505	230							
98	21/2	3 5%	885	405	—								
1/	2	25⁄8	600	420	1,130	790							
72	31⁄2	51⁄4	1,350	945	—								

1. Allowable tension loads are calculated based on the strength design provision of ACI 318-11 Appendix D using a conversion factor of α = 1.4. The conversion factor α is based on the load combination 1.2D + 1.6L assuming 50% dead load and 50% live load: 1.2(0.5) + 1.6(0.5) = 1.4.

2. Tabulated values are for a single anchor with no influence of another anchor.

3. Interpolation between embedment depths is not permitted.

4. Installation must comply with Figure 1 on page 187.

Allowable Tension Load (lb.) Nominal Embed. Minimum End Anchor Dia. Distance c_{min} Depth **Upper Flute** Lower Flute (in.) (in.) (in.) Uncracked Cracked **Uncracked** Cracked 1 5⁄8 21/2 385 165 605 255 1/4 21/2 4 500 210 1.115 465 1 7⁄8 21/2 320 145 425 195 3⁄8 21/2 3% 745 340 2 2% 505 355 950 665 1/2 31/2 51⁄4 1,135 795

Titen HD® Allowable Tension Loads in Soffit of Normal-Weight or Sand-Lightweight Concrete-Filled Profile Steel Deck Assemblies (f'_c = 3,000 psi) — Wind Load

1. Allowable tension loads are calculated based on the strength design provision of ACI 318-11 Appendix D

using a conversion factor of $\alpha = 1.67$. The conversion factor α is based on the load combination assuming 100% wind load.

2. Tabulated values are for a single anchor with no influence of another anchor.

3. Interpolation between embedment depths is not permitted.

4. Installation must comply with Figure 1 on page 187.



IBC

SIMPSO

190

^{4.} Strength reduction factor, ϕ , is based on using a load combination from ACI 318-11 Section 9.2.

Titen HD[®] Allowable Tension Loads in Soffit of Normal-Weight or Sand-Lightweight Concrete-Filled Profile Steel Deck Assemblies (f'_c = 3,000 psi) — Seismic Load

	Nominal	Minimum		Allowable Tension Load (lb.)										
Anchor Dia.	Embed.	End Distance		Lowe	r Flute			Upper Flute						
(in.)	Depth	C _{min}	SDC A-B ⁴		SDC C-F ^{5,6}		SDC A-B ⁴		SDC C-F ^{5,6}					
	(in.)	(in.)	Uncracked	Cracked	Uncracked	Cracked	Uncracked	Cracked	Uncracked	Cracked				
1/	1 5⁄8	2 1⁄2	450	195	340	145	705	300	530	225				
74	21⁄2	4	580	245	435	180	1300	545	975	410				
34	1 1 1/8	2 1/2	375	170	280	130	495	230	375	170				
%8	21/2	3 5/8	870	395	650	300	—	—	—	—				
1⁄2	2	2 5/8	590	415	440	310	1105	775	830	580				
	31⁄2	5 1⁄4	1325	930	995	695	—	—	—	—				

1. Allowable tension loads are calculated based on the strength design provision of ACI 318-11 Appendix D using a conversion factor of $\alpha = \frac{1}{0.7} = 1.43$. The conversion factor α is based on the load combination assuming 100% seismic load.

2. Tabulated values are for a single anchor with no influence of another anchor.

3. Interpolation between embedment depths is not permitted.

4. The allowable tension load listed for SDC (Seismic Design Category) A-B may also be used in SDC C-F when the tension component of the strength-level seismic design load on the anchor does not exceed 20% of the total factored tension load on the anchor associated with the same load combination.

5. When designing anchorages in SDC C-F, the designer shall consider the ductility requirements of ACI 318-11 Section D.3.3.

6. Tension design strengths in SDC C-F have been adjusted by 0.75 factor in accordance with ACI 318-11 Section D.3.3.4.4.

7. Installation must comply with Figure 1 on page 187.

SIMES

Strong



JPC

JBC 📑 🔝

Titen HD® Allowable Tension Loads in Normal-Weight Concrete

			0.00	o	Tension Load						
Size	Drill Bit Dia.	Embed. Depth in.	Dist.	Spacing	f' _c ≥2,000	psi (13.8 MP	a Concrete)	f' _c ≥3,000 psi (20.7 MPa Concrete)	f' _c ≥4,000	psi (27.6 MP	a Concrete)
()	(in.)	(mm)	(mm)	(mm)	Ultimate Ib. (kN)	Std. Dev. Ib. (kN)	Allowable Ib. (kN)	Allowable Ib. (kN)	Ultimate Ib. (kN)	Std. Dev. Ib. (kN)	Allowable Ib. (kN)
		1 ½ (38)	6 (152)	4 (102)	2,070 (9.2)	—	520 (2.3)	635 (2.8)	2,974 (13.2)	_	745 (3.3)
³ / ₈ (9.5)	3⁄8	2¾ (70)	3	6	4,297 (19.1)	_	1,075 (4.8)	1,315 (5.8)	6,204 (27.6)	_	1,550 (6.9)
		3¾ (95)	(76)	(152)	7,087 (31.5)	347 (1.5)	1,770 (7.9)	2,115 (9.4)	9,820 (43.7)	1,434 (6.4)	2,455 (10.9)
		2¾ (70)			4,610 (20.5)	—	1,155 (5.1)	1,400 (6.2)	6,580 (29.3)	_	1,645 (7.3)
¹ / ₂ (12.7)	1⁄2	3% (92)	4 (102)	8 (203)	7,413 (33.0)	412 (1.8)	1,855 (8.3)	2,270 (10.1)	10,742 (47.8)	600 (2.7)	2,685 (11.9)
		5¾ (146)			10,278 (45.7)	297 (1.3)	2,570 (11.4)	3,240 (14.4)	15,640 (69.6)	2,341 (10.4)	3,910 (17.4)
		2¾ (70)			4,610 (20.5)	—	1,155 (5.1)	1,400 (6.2)	6,580 (29.3)	_	1,645 (7.3)
5% (15.9)	5⁄8	41% (105)	5 (127)	10 (254)	8,742 (38.9)	615 (2.7)	2,185 (9.7)	2,630 (11.7)	12,286 (54.7)	1,604 (7.1)	3,070 (13.7)
		5¾ (146)			12,953 (57.6)	1,764 (7.8)	3,240 (14.4)	3,955 (17.6)	18,680 (83.1)	_	4,670 (20.8)
		2¾ (70)			4,674 (20.8)	—	1,170 (5.2)	1,405 (6.3)	6,580 (29.3)	—	1,645 (7.3)
³ ⁄ ₄ (19.1)	3⁄4	4% (117)	6 (152)	12 (305)	10,340 (46.0)	1,096 (4.9)	2,585 (11.5)	3,470 (15.4)	17,426 (77.5)	1,591 (7.1)	4,355 (19.4)
(19.1)		(117) (152) 5% (146)	(000)	13,765 (61.2)	1,016 (4.5)	3,440 (15.3)	4,055 (18.0)	18,680 (83.1)	1,743 (7.8)	4,670 (20.8)	

1. The allowable loads listed are based on a safety factor of 4.0.

2. Refer to allowable load-adjustment factors for spacing and edge distance on pages 198 and 199.

3. The minimum concrete thickness is 1 $\!\!\!\!^{1}\!\!\!_{2}$ times the embedment depth.

4. Tension and shear loads for the Titen HD anchor may be combined using the elliptical interaction equation (n=5%).

Allowable load may be interpolated for concrete compressive strengths between 2,000 psi and 4,000 psi.

Titen HD® Allowable Shear Loads in Normal-Weight Concrete

								Shear Load			
Size (in.)	Drill Bit	Embed. Depth	Critical Edge	Critical Spacing in.	f' _c ≥2,000 p	osi (13.8 MP	a Concrete)	f' _c ≥3,000 psi (20.7 MPa Concrete)	f' _c ≥4,000	psi (27.6 MPa	a Concrete)
				(mm)	Ultimate Ib. (kN)	Std. Dev. Ib. (kN)	Allowable Ib. (kN)	Allowable Ib. (kN)	Ultimate Ib. (kN)	Std. Dev. Ib. (kN)	Allowable Ib. (kN)
		1 ½ (38)	6 (152)	4 (102)	2,912 (13.0)	_	730 (3.2)	825 (3.7)	3,668 (16.3)	—	915 (4.1)
⅔ (9.5)	3⁄8	23⁄4 (70)	41⁄2	6	6,353 (28.3)		1,585 (7.1)	1,665 (7.4)		_	1,740 (7.7)
		3¾ (95)	(114)	(152)	6,377 (28.4)	1,006 (4.5)	1,595 (7.1)	1,670 (7.4)	_	—	1,740 (7.7)
		23⁄4 (70)			6,435 (28.6)	—	1,605 (7.1)	2,050 (9.1)	9,987 (44.4)	—	2,495 (7.8)
½ (12.7)	1⁄2	3% (92)	6 (152)	8 (203)	9,324 (41.5)	1,285 (5.7)	2,330 (10.4)	2,795 (12.4)	13,027 (57.9)	597 (2.7)	3,255 (14.5)
		5¾ (146)			11,319 (50.3)	1,245 (5.5)	2,830 (12.6)	3,045 (13.5)			3,255 (14.5)
		23⁄4 (70)			7,745 (34.5)		1,940 (8.6)	2,220 (9.9)	9,987 (44.4)		2,495 (7.8)
5% (15.9)	5⁄8	41% (105)	7½ (191)	10 (254)	8,706 (38.7)	1,830 (8.1)	2,175 (9.7)	3,415 (15.2)	18,607 (82.8)	1,650 (7.3)	4,650 (20.7)
		5¾ (146)			12,498 (55.6)	2,227 (9.9)	3,125 (13.9)	3,890 (17.3)			4,650 (20.7)
¾ (19.1)		23⁄4 (70)	9 (229)		7,832 (34.8)		1,960 (8.7)	2,415 (10.7)	11,460 (51.0)	—	2,865 (12.7)
	3⁄4	45% (117)		12 (305)	11,222 (49.9)	2,900 (12.9)	2,805 (12.5)	4,490 (20.0)	24,680 (109.8)	2,368 (10.5)	6,170 (27.4)
		5% (146)	(000)	19,793 (88.0)	3,547 (15.8)	4,950 (22.0)	5,560 (24.7)	24,680 (109.8)	795 (3.5)	6,170 (27.4)	

1. The allowable loads listed are based on a safefy factor of 4.0.

2. Refer to allowable load-adjustment factors for spacing and edge distance on pages 198 and 199.

4. Tension and shear loads for the Titen HD anchor may be combined using the elliptical interaction equation (n=5%).

Allowable load may be interpolated for concrete compressive strengths between 2,000 psi and 4,000 psi.

* See page 12 for an explanation of the load table icons.

Titen HD[®] Allowable Shear Loads in Normal-Weight Concrete, Load Applied Parallel to Concrete Edge

Size	Drill Bit	Embed. Depth	Minimum Edge	Minimum End	Minimum Spacing	Shear Load Based on Concrete Edge Distance				
jin.	Dia.	in.	Dist.	Dist.	Dist.	$f'_c \ge 2,500$ psi (17.2 MPa) Concrete				
(mm)	in.	(mm)	ın. (mm)	in. (mm)	in. (mm)	Ultimate Ib. (kN)	Std. Dev. Ib. (kN)	Allowable lb. (kN)		
		2¾ (70)	1% (45)		8 (203)	4,660 (20.7)	575 (2.6)	1,165 (5.2)		
1/2	1/	31⁄4 (83)		8 (203)		—	—	1,530 (6.8)		
(12.7)	/2	3½ (89)				6,840 (30.4)	860 (3.8)	1,710 (7.6)		
		4½ (114)				7,800 (34.7)	300 (1.3)	1,950 (8.7)		
		2¾ (70)				4,820 (21.4)	585 (2.6)	1,205 (5.3)		
% (15.9)	5⁄8	31⁄4 (83)	13⁄4 (45)	10 (254)	10 (254)	—	—	1,580 (7.0)		
		3½ (89)				7,060 (31.4)	1,284 (5.7)	1,765 (7.9)		

IBC



Note: Rebar not shown for clarity.

1. The allowable loads listed are based on a safety factor of 4.0.

2. The minimum concrete thickness is 11/2 times the embedment depth.

Titen HD[®] Allowable Tension Loads in Normal-Weight Concrete Stemwall

						Tensio	n Load		
Size in.	Drill Bit Dia.	Embed. Depth in.	Stemwall Width in.	III Min. Min. Edge End Dist. Dist.		f ^ı _c ≥ 2,500 psi (17.2 MPa) Concrete		f' _c ≥ 4,500 psi (31.0 MPa) Concrete	
(mm)	in.	(mm)	(mm)	in. (mm)	in. (mm)	Ultimate Ib. (kN)	Allow. Ib. (kN)	Ultimate Ib. (kN)	Allow. Ib. (kN)
1/2		10	6	1¾	8 (203)	15,420 (68.6)	3,855 (17.1)	20,300 (90.3)	5,075 (22.6)
(12.7)	1/2	(254)	(152)	(45)	4% (111)	14,280 (63.5)	3,570 (15.9)	19,040 (84.7)	4,760 (21.2)

1. The allowable loads are based on a safety factor of 4.0.

2. The minimum anchor spacing is 15 inches.

3. The minimum concrete thickness (depth) is 12 inches.

4. Allowable loads may be interpolated for compressive strengths between 2,500 and 4,500 psi.

Titen HD [®] Allowable Tension Loads in	Norm	al-We	eight
Concrete, Load Applied at 60° Angle	IRC		Ē
o Horizontal for Tilt-Up Wall Braces		22 22	

		Embed	Tension Applied at 60 degrees to Horizontal					
Size in. (mm)	Drill Bit Dia. in.	Depth in.	f' _c ≥ 2,500 psi (17.2 MPa) Concrete					
		(11111)	Ultimate Ib. (kN)	Std. Dev. Ib. (kN)	Allow. Ib. (kN)			
5⁄8 (15.9)	5⁄8	5 (127)	13,420 (59.7)	1,273 (5.7)	3,355 (14.9)			
3⁄4 (19.1)	3⁄4	5 (127)	15,180 (67.5)	968 (4.3)	3,795 (16.9)			

1. The allowable loads are based on a safety factor of 4.0.

 Anchor must be installed into a concrete floor slab, footing, or deadman with sufficient area, weight, and strength to resist the anchorage load.

3. Titen HD[®] has been qualified for temporary outdoor use of up to 90 days through testing for this application.



The Titen HD[®] screw anchor $\frac{3}{4}$ " x 6" and $\frac{3}{4}$ " x 7" (models THDT75600H and THD75700H) have a 1" section under the head that is unthreaded to allow installation into tilt-up wall braces.

* See page 12 for an explanation of the load table icons.

SIMPSO

Strong



IBC

Titen HD® Allowable Tension and Shear Loads in Sand-Lightweight Concrete over Metal Deck

					Inst	tall in Concrete	(see Figure bel	ow)	Install t	hrough Metal D	eck (see Figure	below)		
Cizo	Drill	Embed.	Critical	Critical	Tensio	n Load	Shear	⁻ Load	Tensio	n Load	Shear Load			
in. (mm)	Bit Dia.	Depth in.	Dist. Dist.	Dist. in. (mm)	f' _c ≥ 3,000 psi (20.7 MPa) Lightweight Concrete		f' _c ≥ 3,000 psi (20.7 MPa) Lightweight Concrete		f' _c ≥ 3,000 psi (20.7 MPa) Lightweight Concrete		f' _c ≥ 3,000 psi (20.7 MPa) Lightweight Concrete			
			(mm)		Ultimate Ib. (kN)	Allowable lb. (kN)	Ultimate Ib. (kN)	Allowable Ib. (kN)	Ultimate Ib. (kN)	Allowable lbs. (kN)	Ultimate Ib. (kN)	Allowable lb. (kN)		
3⁄8	34	2¾ (70)	6	6	2,560 (11.4)	640 (2.8)	4,240 (18.9)	1,060 (4.7)	—	—	—	—		
(9.5)	98	3 (76)	(152)	(152)	—			—	5,420 (24.1)	1,355 (6.0)	4,100 (18.2)	1,025 (4.6)		
1/2	1/-	2¾ (70)	8 8		3,040 (13.5)	760 (3.4)	6,380 (28.4)	1,595 (7.1)	—	—	—	—		
(12.7)	72	4 (102)	(203)	(203)	(203)	(203)	—			—	7,020 (31.2)	1,755 (7.8)	6,840 (30.4)	1,710 (7.6)
5% (15.9) 5%	5/	23⁄4 (70)	10	10 (254)	3,100 (13.8)	775 (3.4)	6,380 (28.4)	1,595 (7.1)	—	—	—	—		
	78	5 (127)	(254)		_			_	8,940 (39.8)	2,235 (9.9)	10,700 (47.6)	2,675 (11.9)		

1. The allowable loads listed are based on a safety factor of 4.0.

2. Allowable loads for anchors installed in the lower flute of the steel deck are for flutes with a trapezoidal profile with a depth of 3 inches, and a width varying from 41½ inches at the bottom to 71½ inches at the top. The spacing of the flutes is 12 inches. The metal deck must be minimum 20-gauge with a minimum yield strength of 38 ksi and minimum ultimate strength of 45 ksi.

3. Anchors may be installed off-center in the lower flute (up to 1 ½" from the edge of the lower flute) without a load reduction.

4.100% of the allowable load is permitted at critical edge distance and critical spacing. Testing at smaller edge distances and spacings has not been performed.



Titen HD[®] screw anchor installed in the top and bottom of a structural sand-lightweight-concrete and metal-deck assembly

C-A-2016 @ 2015 SIMPSON STRONG-TIE COMPANY INC.

Titen HD[®] Design Information — Masonry

Titen HD[®] Allowable Tension and Shear Loads in 8" Lightweight, Medium-Weight and Normal-Weight Grout-Filled CMU

Size Drill		Min. Embed. Depth	Min. Embed. Depth	Critical Edge	Critical End	Critical Spacing	Values for or N	[•] 8-inch Lightv ormal-Weight	weight, Mediu Grout-Filled	ım-Weight CMU
in.	Dia.	Depth	Dist.	Dist.	Dist.	Tensio	n Load	Shear Load		
(mm) in.		in. (mm)	in. (mm)	in. (mm)	in. (mm)	Ultimate Ib. (kN)	Allowable lb. (kN)	Ultimate Ib. (kN)	Allowable lb. (kN)	
		A	Anchor Ins	talled in t	he Face of	the CMU Wal	I (See Figure	4)		
3%8 (9.5)	3⁄8	2¾ (70)	12 (305)	12 (305)	6 (152)	2,390 (10.6)	480 (2.1)	4,340 (19.3)	870 (3.9)	
1⁄2 (12.7)	1⁄2	3½ (89)	12 (305)	12 (305)	8 (203)	3,440 (15.3)	690 (3.1)	6,920 (30.8)	1,385 (6.2)	
5%8 (15.9)	5⁄8	4½ (114)	12 (305)	12 (305)	10 (254)	5,300 (23.6)	1,060 (4.7)	10,420 (46.4)	2,085 (9.3)	
3⁄4 (19.1)	3⁄4	5½ (140)	12 (305)	12 (305)	12 (305)	7,990 (35.5)	1,600 (7.1)	15,000 (66.7)	3,000 (13.3)	

1. The tabulated allowable loads are based on a safety factor of 5.0 for installations under the IBC and IRC.

2. Values for 8-inch-wide, lightweight, medium-weight and normal-weight concrete masonry units.

3. The masonry units must be fully grouted.

4. The minimum specified compressive strength of masonry, f'm, at 28 days is 1,500 psi.

5. Embedment depth is measured from the outside face of the concrete masonry unit.

6. Allowable loads may be increased 331/3% for short-term loading due to wind or seismic forces where permitted by code.

7. Grout-filled CMU wall design must satisfy applicable design standards and be capable of withstanding applied loads.

8. Refer to allowable load-adjustment factors for spacing and edge distance on page 200.

Titen HD[®] Allowable Tension and Shear Loads in 8" Lightweight, Medium-Weight and Normal-Weight Hollow CMU

Sizo Drill		Embed.	Min.	Min.	8-iı	nch Hollow C on CMU	MU Loads Based Strength			
Size in. (mm)	Bit Dia.	Depth⁴ in.	Dist. Dist.	Dist.	Tension Load		Shear Load			
()	in.	(mm)	(mm)	(mm)	Ultimate Ib. (kN)	Allowable lb. (kN)	Ultimate Ib. (kN)	Allowable lb. (kN)		
		An	chor Install	ed in Face S	Shell (See Fig	jure 5)				
3⁄8 (9.5)	3⁄8	1 ¾ (45)	4 (102)	4% (117)	720 (3.2)	145 (0.6)	1,240 (5.5)	250 (1.1)		
½ (12.7)	1⁄2	1¾ (45)	4 (102)	4% (117)	760 (3.4)	150 (0.7)	1,240 (5.5)	250 (1.1)		
⁵% (15.9)	5⁄8	1 ¾ (45)	4 (102)	4% (117)	800 (3.6)	160 (0.7)	1,240 (5.5)	250 (1.1)		
3⁄4 (19.1)	3⁄4	1¾ (45)	4 (102)	4% (117)	880 (3.9)	175 (0.8)	1,240 (5.5)	250 (1.1)		

1. The tabulated allowable loads are based on a safety factor of 5.0 for installations under the IBC and IRC.

2. Values for 8-inch-wide, lightweight, medium-weight and normal-weight concrete masonry units.

3. The minimum specified compressive strength of masonry, f'm, at 28 days is 1,500 psi.

4. Embedment depth is measured from the outside face of the concrete masonry unit and is based on the anchor being embedded an additional 1/2" through 1 1/4" thick face shell.

5. Allowable loads may not be increased for short-term loading due to wind or seismic forces. CMU wall design must satisfy applicable design standards and be capable of withstanding applied loads.

6. Do not use impact wrenches to install in hollow CMU.

7. Set drill to rotation-only mode when drilling into hollow CMU.



Critical edge distance (see load table)

Figure 4. Shaded Area = Placement for Full and Reduced Allowable Load Capacity in Grout-Filled CMU







Titen HD® Allowable Tension and Shear Loads in 8" Lightweight, Medium-Weight and Normal-Weight Grout-Filled CMU Stemwall

Sizo Dril		Embed.	Min.	n. Min. Ie End	Critical	8-inch Grout-Filled CMU Allowable Loads Based on CMU Strength								
Size in.	Bit	Depth	Edge Dist.	End Dist.	Spacing Dist.	Tension		Shear Per	p. to Edge	Shear Parallel to Edge				
(mm)	in.	(mm)	in. (mm)	in. (mm)	in. (mm)	Ultimate Ib. (kN)	Allowable lb. (kN)	Ultimate Ib. (kN)	Allowable lb. (kN)	Ultimate Ib. (kN)	Allowable lb. (kN)			
	Anchor Installed in Cell Opening or Web (Top of Wall) (See Figure 6)													
1⁄2 (12.7)	1⁄2	4½ (114)	13⁄4 (45)	8 (203)	8 (203)	2,860 (12.7)	570 (2.5)	800 (3.6)	160 (0.7)	2,920 (13.0)	585 (2.6)			
5%8 (15.9)	5⁄8	4½ (114)	13⁄4 (45)	10 (254)	10 (254)	2,860 (12.7)	570 (2.5)	800 (3.6)	160 (0.7)	3,380 (15.0)	675 (3.0)			

IBC

1. The tabulated allowable loads are based on a safety factor of 5.0 for installations under the IBC and IRC.

Values are for 8-inch-wide, lightweight, medium-weight and normal-weight concrete masonry units.
 The masonry units must be fully grouted.

4. The minimum specified compressive strength of masonry, f'_m , at 28 days is 1,500 psi.

5. Allowable loads may be increased 33 1/3% for short-term loading due to wind or seismic forces where permitted by code.

6. Grout-filled CMU wall design must satisfy applicable design standards and be capable of withstanding applied design loads.

7. Loads are based on anchor installed in either the web or grout-filled cell opening in the top of wall.





Figure 6. Anchor Installed in top of wall

* See page 12 for an explanation of the load table icons.

Titen HD® Design Information — Masonry

Titen HD[®] Allowable Tension Loads for 8" Lightweight, Medium-Weight and Normal-Weight CMU Chair Blocks Filled with Normal-Weight Concrete



SIMPSON

Strong-T

Size in.	Drill Bit Dia.	Min. Embed. Depth	Min. Edge Dist.	Critical Spacing	8-inch Concrete-Fil Allowable Tension Loads	led CMU Chair Block s Based on CMU Strength
(mm)	(in.)	(mm)	(mm)	(mm)	Ultimate lb. (kN)	Allowable lb. (kN)
		2% (60)	1 ¾ (44)	9½ (241)	3,175 (14.1)	635 (2.8)
3% (9.5)	3⁄8	3% (86)	1 ¾ (44)	13½ (343)	5,175 (23.0)	1,035 (4.6)
		5 (127)	21⁄4 (57)	20 (508)	10,584 (47.1)	2,115 (9.4)
1/2	1/	8 (203)	21⁄4 (57)	32 (813)	13,722 (61.0)	2,754 (12.2)
(12.7)	72	10 (254)	21⁄4 (57)	40 (1016)	16,630 (74.0)	3,325 (14.8)
5/8	5/	5½ (140)	1 ¾ (44)	22 (559)	9,025 (40.1)	1,805 (8.1)
(15.9)	9/8	12 (305)	21/4 (57)	48 (1219)	18,104 (80,5)	3,620 (16,1)

1. The tabulated allowable loads are based on a safety factor of 5.0.

2. Values are for 8-inch-wide concrete masonry units (CMU) filled with concrete, with minimum compressive strength of 2,500 psi and poured monolithically with the floor slab.

3. Center #5 rebar in CMU cell and concrete slab as shown in the illustration below.





Load Adjustment Factors for Titen HD[®] Anchors in Normal-Weight Concrete: Edge Distance, Tension and Shear Loads

How to use these charts:

- 1. The following tables are for reduced edge distance.
- 2. Locate the anchor size to be used for either a tension
- and/or shear load application. 3. Locate the anchor embedment (E) used for either a tension
- Locate the anchor embedment (E) used for either a tension and/or shear load application.
- 4. Locate the edge distance (c_{act}) at which the anchor is to be installed. 5. The load adjustment factor (f_c) is the intersection of the row and
- 5. The load adjustment factor (I_c) is the intersection of the row and column.
- 6. Multiply the allowable load by the applicable load adjustment factor(s).
- 7. Reduction factors for multiple edges are multiplied together.

IBC

Edge	Distan	ce Ter	nsion (f)									
	Dia.		3⁄8			1/2			5⁄8			3⁄4	
Edge	Ε	1½	2¾	3¾	23⁄4	35⁄8	5¾	23⁄4	41⁄8	5¾	23⁄4	4 %	5¾
Dist.	Ccr	6	3	3	4	4	4	5	5	5	6	6	6
(in)	C _{min}	6	1¾	1¾	1¾	1¾	1¾	1¾	1¾	1¾	1¾	1¾	13⁄4
()	f _{cmin}	1.00	0.83	0.73	0.67	0.57	0.73	0.67	0.57	0.59	0.67	0.48	0.58
1 3⁄4			0.83	0.73	0.67	0.57	0.73	0.67	0.57	0.59	0.67	0.48	0.58
2			0.86	0.78	0.71	0.62	0.76	0.70	0.60	0.62	0.69	0.51	0.60
21⁄4			0.90	0.84	0.74	0.67	0.79	0.72	0.64	0.65	0.71	0.54	0.63
21/2			0.93	0.89	0.78	0.71	0.82	0.75	0.67	0.68	0.73	0.57	0.65
23⁄4			0.97	0.95	0.82	0.76	0.85	0.77	0.70	0.72	0.75	0.60	0.68
3			1.00	1.00	0.85	0.81	0.88	0.80	0.74	0.75	0.77	0.63	0.70
31⁄4					0.89	0.86	0.91	0.82	0.77	0.78	0.79	0.66	0.73
31⁄2					0.93	0.90	0.94	0.85	0.80	0.81	0.81	0.69	0.75
3¾					0.96	0.95	0.97	0.87	0.83	0.84	0.83	0.72	0.78
4					1.00	1.00	1.00	0.90	0.87	0.87	0.84	0.76	0.80
41⁄4								0.92	0.90	0.91	0.86	0.79	0.83
41⁄2								0.95	0.93	0.94	0.88	0.82	0.85
43⁄4								0.97	0.97	0.97	0.90	0.85	0.88
5								1.00	1.00	1.00	0.92	0.88	0.90
51⁄4											0.94	0.91	0.93
51⁄2											0.96	0.94	0.95
5¾											0.98	0.97	0.98
6		1.00									1.00	1.00	1.00

See notes below.

Edge Distance Shear (f_c)

Eage I	Distant	ce Sne	ear (I _c)							Ľ			N SCHOOL
	Dia.		3⁄8			1⁄2			5⁄8			3⁄4	
Edge	Ε	1½	23⁄4	3¾	23⁄4	3%	5¾	23⁄4	41⁄8	5¾	2¾	45%8	5¾
Dist.	Ccr	6	41⁄2	41⁄2	6	6	6	71⁄2	7½	7½	9	9	9
(in)	C _{min}	6	1¾	1¾	1¾	1¾	1¾	1¾	1¾	1¾	1¾	1¾	1¾
()	f _{cmin}	1.00	0.25	0.24	0.25	0.20	0.17	0.19	0.16	0.19	0.19	0.14	0.13
1 3⁄4			0.25	0.24	0.25	0.20	0.17	0.19	0.16	0.19	0.19	0.14	0.13
2			0.32	0.31	0.29	0.25	0.22	0.23	0.20	0.23	0.22	0.17	0.16
21/2			0.45	0.45	0.38	0.34	0.32	0.30	0.27	0.30	0.27	0.23	0.22
3			0.59	0.59	0.47	0.44	0.41	0.37	0.34	0.37	0.33	0.29	0.28
31⁄2			0.73	0.72	0.56	0.53	0.51	0.44	0.42	0.44	0.39	0.35	0.34
4			0.86	0.86	0.65	0.62	0.61	0.51	0.49	0.51	0.44	0.41	0.40
4 1/2			1.00	1.00	0.74	0.72	0.71	0.58	0.56	0.58	0.50	0.47	0.46
5					0.82	0.81	0.80	0.65	0.63	0.65	0.55	0.53	0.52
51⁄2					0.91	0.91	0.90	0.72	0.71	0.72	0.61	0.58	0.58
6		1.00			1.00	1.00	1.00	0.79	0.78	0.79	0.66	0.64	0.64
61⁄2								0.86	0.85	0.86	0.72	0.70	0.70
7								0.93	0.93	0.93	0.78	0.76	0.76
71/2								1.00	1.00	1.00	0.83	0.82	0.82
8											0.89	0.88	0.88
81⁄2											0.94	0.94	0.94
9											1.00	1.00	1.00

The tabled adjustment values (f_{c}) have been calculated using the following information:

1. E = Embedment depth (inches).

2. *c_{act}* = actual edge distance at which anchor is installed (inches).

3. c_{cr} = critical edge distance for 100% load (inches).

4. *c_{min}* = minimum edge distance for reduced load (inches).

5. f_c = percent of allowable load at actual edge distance.

6. f_{ccr} = percentage of allowable load at critical edge

distance. f_{ccr} is always = 1.00.

7. f_{cmin} = percent of allowable load at minimum edge distance.

 $8. f_c = f_{cmin} + \left[\left(1 - f_{cmin} \right) \left(c_{act} - c_{min} \right) / \left(c_{cr} - c_{min} \right) \right].$

* See page 12 for an explanation of the load table icons.

Titen HD® Design Information - Concrete

SIMPSON Strong-Tie

Load Adjustment Factors for Titen HD[®] Anchors in Normal-Weight Concrete: Edge Distance, Tension and Shear Loads

How to use these charts:

- 1. The following tables are for reduced edge distance.
- 2. Locate the anchor size to be used for either a tension and/or a shear load application.
- 3. Locate the anchor embedment (E) used for either a tension and/or a shear load application.
- 4. Locate the edge distance (s_{act}) at which the anchor is to be installed.
- 5. The load adjustment factor (f_s) is the intersection of the row and column.
- 6. Multiply the allowable load by the applicable load adjustment factor(s).
- 7. Reduction factors for multiple edges are multiplied together.

Spac	ing Ter	nsion ((f _s)							J	x		
	Dia.		3⁄8			1⁄2			5⁄8			3⁄4	
	Ε	11/2	23⁄4	3¾	23⁄4	35⁄8	5¾	23⁄4	41⁄8	5¾	23⁄4	4 5/8	5¾
Sact (in)	S _{cr}	4	6	6	8	8	8	10	10	10	12	12	12
(11)	S _{min}	4	11/2	1½	2	2	2	21/2	21⁄2	21⁄2	3	3	3
	f _{smin}	1.00	0.66	0.56	0.72	0.63	0.76	0.79	0.69	0.73	0.80	0.70	0.72
1													
1 1⁄2			0.66	0.56									
2			0.70	0.61	0.72	0.63	0.76						
21⁄2			0.74	0.66	0.74	0.66	0.78	0.79	0.69	0.73			
3			0.77	0.71	0.77	0.69	0.80	0.80	0.71	0.75	0.80	0.70	0.72
4		1.00	0.85	0.80	0.81	0.75	0.84	0.83	0.75	0.78	0.82	0.73	0.75
5			0.92	0.90	0.86	0.82	0.88	0.86	0.79	0.82	0.84	0.77	0.78
6			1.00	1.00	0.91	0.88	0.92	0.89	0.83	0.86	0.87	0.80	0.81
7					0.95	0.94	0.96	0.92	0.88	0.89	0.89	0.83	0.84
8					1.00	1.00	1.00	0.94	0.92	0.93	0.91	0.87	0.88
9								0.97	0.96	0.96	0.93	0.90	0.91
10								1.00	1.00	1.00	0.96	0.93	0.94
11											0.98	0.97	0.97
12											1.00	1.00	1.00

See notes below

Spacing Shear (f_s)

Space	ing Si	iear (is	s)							e.			
	Dia.		3⁄8			1⁄2			5⁄8			3⁄4	
	Ε	11/2	23⁄4	3¾	23⁄4	35%8	5¾	23⁄4	41⁄8	5¾	23⁄4	4 %	5¾
S _{act}	s _{cr}	4	0	0	0	0	0	0	0	0	0	0	0
(11)	S _{min}	4	0	0	0	0	0	0	0	0	0	0	0
	f _{smin}	1.00	0.77	0.77	0.77	0.77	0.77	0.77	0.77	0.77	0.77	0.77	0.77
1													
1 1⁄2			0.77	0.77	0.88								
2			0.80	0.80	0.77	0.77	0.77						
21⁄2			0.82	0.82	0.79	0.79	0.79	0.77	0.77	0.77			
3			0.85	0.85	0.81	0.81	0.81	0.79	0.79	0.79	0.77	0.77	0.77
4		1.00	0.90	0.90	0.85	0.85	0.85	0.82	0.82	0.82	0.80	0.80	0.80
5			0.95	0.95	0.89	0.89	0.89	0.85	0.85	0.85	0.82	0.82	0.82
6			1.00	1.00	0.92	0.92	0.92	0.88	0.88	0.88	0.85	0.85	0.85
7					0.96	0.96	0.96	0.91	0.91	0.91	0.87	0.87	0.87
8					1.00	1.00	1.00	0.94	0.94	0.94	0.90	0.90	0.90
9								0.97	0.97	0.97	0.92	0.92	0.92
10								1.00	1.00	1.00	0.95	0.95	0.95
11											0.97	0.97	0.97
12											1.00	1.00	1.00

The tabled adjustment values $(f_{\rm s})$ have been calculated using the following information:

1. E = Embedment depth (inches).

- 2. s_{act} = actual spacing distance at which anchors are installed (inches).
- 3. s_{cr} = critical spacing distance for 100% load (inches).

4. *s_{min}* = minimum spacing distance for reduced load (inches).

5. f_s = adjustment factor for allowable load at actual spacing distance.

- 6. f_{SCT} = adjustment factor for allowable load at critical spacing distance. f_{SCT} is always = 1.00.
- f_{smin} = adjustment factor for allowable load at minimum spacing distance.
- 8. $f_s = f_{smin} + [(1 f_{smin}) (s_{act} s_{min}) / (s_{cr} s_{min})].$

Titen HD® Design Information - Masonry



Load-Adjustment Factors for Titen HD[®] Anchors in Face-of-Wall Installation in 8" Grout-Filled CMU: Edge Distance and Spacing, Tension and Shear Loads

How to use these charts:

- 1. The following tables are for reduced edge distance and spacing.
- Locate the anchor size to be used for either a tension and/or shear load application.
- 3. Locate the embedment (E) at which the anchor is to be installed.
- Locate the edge distance (c_{act}) or spacing (s_{act}) at which the anchor is to be installed.

Edge or End Distance Tension (f_c)

	Dia.	3F8	1/2	5F8	3F4	IBC
	E	4 1/2	31⁄2	41⁄2	4 1⁄2	
C _{act} (in)	C _{cr}	12	12	12	12	
()	C _{min}	4	4	4	4	20 20
	f _{cmin}	1.00	1.00	0.83	0.66	(
4		1.00	1.00	0.83	0.66	
6		1.00	1.00	0.87	0.75	
8		1.00	1.00	0.92	0.83	
10		1.00	1.00	0.96	0.92	
12		1.00	1.00	1.00	1.00	

See notes below

Mechanical Anchors

Edge or End Distance Shear (f_c) Shear Load Perpendicular to Edge or End (Directed Towards Edge or End)

0	· ·		0	,		
	Dia.	3⁄8	1/2	5⁄8	3⁄4	
	E	23⁄4	31⁄2	4 1⁄2	5 ½	
C _{act}	C _{cr}	12	12	12	12	-
()	C _{min}	4	4	4	4	257 252
	f _{cmin}	0.58	0.38	0.30	0.21	(
4		0.58	0.38	0.30	0.21	
6		0.69	0.54	0.48	0.41	
8		0.79	0.69	0.65	0.61	
10		0.90	0.85	0.83	0.80	
12		1.00	1.00	1.00	1.00	
12		1.00	1.00	1.00	1.00	

1.E = Embedment depth (inches).

2. cact = actual end or edge distance at which anchor is installed (inches).

3. c_{cr} = critical end or edge distance for 100% load (inches).

4. c_{min} = minimum end or edge distance for reduced load (inches).

5. f_c = adjustment factor for allowable load at actual end or edge distance.

6. f_{ccr} = adjustment factor for allowable load at critical end or edge distance. f_{ccr} is always = 1.00.

7. f_{cmin} = adjustment factor for allowable load at minimum end or edge distance. 8. $f_c = f_{cmin} + [(1 - f_{cmin}) (c_{act} - c_{min}) / (c_{cr} - c_{min})].$

Spacing Tension (f₂)

	0	(3)			
	Dia.	3⁄8	1/2	5⁄8	3⁄4
_	E	23⁄4	3 1/2	4 1⁄2	5 ½
S _{act}	S _{cr}	6	8	10	12
()	S _{min}	3	4	5	6
	f _{smin}	0.87	0.69	0.59	0.50
3		0.87			
4		0.91	0.69		
5		0.96	0.77	0.59	
6		1.00	0.85	0.67	0.50
8			1.00	0.84	0.67
10				1.00	0.83
12					1.00

1. E = Embedment depth (inches).

2. s_{act} = actual spacing distance at which anchors are installed (inches).

3. s_{cr} = critical spacing distance for 100% load (inches).

 $4. s_{min}$ = minimum spacing distance for reduced load (inches).

5. f_s = adjustment factor for allowable load at actual spacing distance.

6. f_{scr} = adjustment factor for allowable load at critical spacing distance. f_{scr} is always = 1.00. 7. f_{smin} = adjustment factor for allowable load at minimum spacing distance.

 $8. f_s = f_{smin} + [(1 - f_{smin}) (s_{act} - s_{min}) / (s_{cr} - s_{min})].$

* See page 12 for an explanation of the load table icons.

 The load adjustment factor (f_c or f_s) is the intersection of the row and column.
 Multiply the allowable load by the applicable load adjustment factor.

Edge and End Distance Shear (f_c)

7. Reduction factors for multiple edges or spacings are multiplied together.

Shear	Load F	Parallel t	o Edge	or End		
	Dia.	3/8	1/2	5⁄8	3/4	IBC
_	E	23⁄4	3½	41⁄2	4½	
Cact	C _{cr}	12	12	12	12	-
()	C _{min}	4	4	4	4	252 255
	f _{cmin}	0.77	0.48	0.46	0.44	(
4		0.77	0.48	0.46	0.44	
6		0.83	0.61	0.60	0.58	
8		0.89	0.74	0.73	0.72	
10		0.94	0.87	0.87	0.86	(Lesters)
12		1.00	1.00	1.00	1.00	

See notes below

Edge or End Distance Shear (f_c) Shear Load Perpendicular to Edge or End (Directed Away From Edge or End)

- (-)		- 0	- /
	Dia.	3⁄8	1⁄2	5⁄8	3⁄4
	E	23⁄4	31⁄2	4 1/2	51⁄2
C _{act}	C _{cr}	12	12	12	12
()	C _{min}	4	4	4	4
	f _{cmin}	0.89	0.79	0.58	0.38
4		0.89	0.79	0.58	0.38
6		0.92	0.84	0.69	0.54
8		0.95	0.90	0.79	0.69
10		0.97	0.95	0.90	0.85
12		1.00	1.00	1.00	1.00

Spacing Shear (f_s)

	Dia.	3⁄8	1/2	5⁄8	3⁄4
_	E	2¾	31⁄2	4 1⁄2	51⁄2
S _{act}	S _{cr}	6	8	10	12
()	S _{min}	3	4	5	6
	f _{smin}	0.62	0.62	0.62	0.62
3		0.62			
4		0.75	0.62		
5		0.87	0.72	0.62	
6		1.00	0.81	0.70	0.62
8			1.00	0.85	0.75
10				1.00	0.87
12					1.00